

Building Safety Certificate

No. 967


Dated:- 27-5-23

Certified that the existing building of Green Valley Educational Institute at Ellahibagh Buchpora comprised of (0) zero basement(s) and (04) four storeys owned / occupied by Green Valley Educational institute have complied with the building safety requirements in accordance with National Building code rules and verified by the officers concerned of PW(R&B) Department on 27-08-2022 in presence of Mohammad Yousuf Wani Chairman and that the building / premises is fit for occupancy upto classes XII with effect from 05-09-2022 issued vide this office No. EE/RRCR/CS/3569, Dt: 05-09-2022 for a period of one (01) year in accordance with rule and subject to compliance of the specified conditions as appended.

1. To put more fire extinguishers in the school premises.
2. Fix Vcon grills on windows for safety purpose after proper consultation with structural consultant.

Attested PC




Principal
Green Valley
Educational Institute
Srinagar

Signature with Seal

Name:- Ex. G. M. MALIK

Designation:- 1/G. Ex-Engineer

